



# Why fuel flexible CFBs are the future



CLECO's Brame Energy Center

### Only circulating fluidized bed combustion technology satisfies all of the often contradictory design requirements of modern solid fuel plants, writes Robert Giglio

**N**ew wind and solar projects continue to dominate recent global capacity increases.

But when dispatchable power is required, particularly in developing countries, coal remains the fuel of choice for utility-scale plants. Global coal use for power generation continues to rise primarily due to rapid growth of the Indian, African, and Asian power markets that value low cost solid fuels.

Every steam plant built today has unique design fuel requirements. For example, economic and policy constraints often dictate use of difficult to burn indigenous fuels or co-firing with biomass or agro fuels.

Also, in most power markets, flexible yet reliable plant operations – such as rapid dispatch rates and spinning reserve – are essential because renewable assets, particularly rapidly fluctuating solar and wind generators, are positioned higher in the dispatch order.

Finally, plant owners desire the least expensive fuel available, often sourced globally, to avoid being tethered to a single fuel for the life of the plant. Only circulating fluidized bed (CFB) combustion technology satisfies all of these often-contradictory design requirements.

#### Fuel markets in flux

The traditional 6000 kcal/kg global steam coal market has flourished for the past 50 years but lately the market has experienced a rapid transition where price often trumps quality.

As coal mines mature, mining operations move to lower quality coal seams. Indonesian coal, for example, dominates the global coal market with about 50 per cent of its exports being high-moisture, sub-bituminous coals with gross-as-received higher heating value (HHV) ranging between 3,900-4,200 kcal/kg.

Furthermore, the best-quality Indonesian coal reserves are expected to produce coals with average HHV no greater than 5200 kcal/kg (with economical washing levels) in the future. The resulting trend is a growing supply of discounted coals, domestic lignites,

and waste coals that provide a significant economic advantage for fuel-flexible plants capable of burning these lower rank, less expensive fuels.

The shift toward a more flexible solid fuel market, where buyers and sellers are pleased to trade fuel quality for price, appears to be permanent.

Expanding low quality solid fuel markets have dramatically increased the value of fuel flexibility for utility-scale power plants and have been the primary driver behind the large CFB power plants coming on-line over the last 10 years, examples of which are included at the end of this article.

CFB plants, unlike pulverized coal (PC) plant designs, give plant owners a choice whether to stay with premium steam coal or to venture into the broader fuels market and leverage the available price discounts for lower rank coals, even for ultra-supercritical plant designs.

#### Fuel combustion flexibility

Changes in the global solid fuel market provide a market advantage to owners of plants that are fuel agnostic. But fuel flexibility means more than just being able to burn a wide range of coals or even coal and biomass mixes. It also means that plant reliability, maintenance, ease of operation, and stack emissions must be largely unaffected over a very wide range of fuel quality including coal and biomass fuel mixes.

PC boilers have trouble burning low quality fuels due to its narrow fuel specification that typically demands 5500 kcal/kg (23 MJ/kg) HHV or higher energy content, fuel moisture below 30-35 per cent, and volatility above 20 per cent.

However, this is not the case for CFB technology. Modern CFBs can efficiently burn both low rank coals and lignites with heating values ranging from 1000 to 8500 kcal/kg (4 to 35 MJ/kg), fuel ash and moisture levels as high as 60 per cent and volatiles down to 5 per cent.

The CFB's high reliability when burning low rank coals is based on its unique flameless, low-temperature combustion process. Unlike

conventional PC boilers that rely on an open flame, the CFB's circulating solids are used to achieve high combustion and heat transfer efficiency. Fuel circulates until completely burned. The ash in the fuel does not melt or soften at low bed temperatures which allows the CFB to avoid the fouling and corrosion problems encountered in conventional boilers.

From an environmental aspect, the low temperature CFB combustion process minimizes NO<sub>x</sub> formation and allows limestone to be fed directly into the furnace to capture SO<sub>x</sub> as the fuel burns. In most cases, SCR and flue gas desulphurization (FGD) systems are not needed for NO<sub>x</sub> and SO<sub>x</sub> control, dramatically reducing the plant's first cost, annual O&M cost, and water consumption while improving overall plant reliability and efficiency.

For a PC boiler to control fouling, slagging, and corrosion when burning low rank coals, such as high sodium lignite, the furnace cross section and height must increase considerably, as much as 45 per cent in height and 60 per cent in footprint.

Also, unlike a PC, a CFB doesn't need soot blowers to control the build-up of deposits and slag in the furnace since the circulating solids keep the furnace walls, panels and steam coils clean, allowing for the most efficient heat transfer possible while reducing boiler maintenance.

Thermographs of CFB and PC furnaces illustrate the thermodynamic differences between the two combustion technologies (Figure 1). The green regions are where the



Lagisza CFB Power plant is the longest-operating supercritical CFB power plant in the world

combustion temperature is around 850C while the red regions show temperatures nearly at 2000C.

The key design criteria for the CFB is that the combustion temperature (everywhere) is well below the fuel's ash melting temperature. Since the ash doesn't melt, fouling and corrosion is minimized throughout the entire boiler (furnace and convection pass) allowing the CFB to achieve reliabilities unreachable by PC boilers.

The lower combustion temperatures minimize the amount of NO<sub>x</sub> formed, often allowing the plant to avoid the expense of an SCR. In addition, limestone can be added directly into the furnace to capture acid gases like SO<sub>2</sub>, SO<sub>3</sub>, HCl, and HF preventing these corrosive elements from causing corrosion

and fouling for throughout boiler, air heater and particulate matter control equipment. In most projects, adding limestone to the CFB can achieve the required SO<sub>2</sub> stack emission without the need for a downstream FGD.

Finally, unlike PC boilers, the fuel doesn't have to be finely ground, dried or dispersed into the furnace by burners avoiding the cost and maintenance of fuel dryers, mills, coal pipes and burners. For the CFB, the fuel is coarsely ground and dropped into fuel chutes using gravity to get the fuel into the boiler.

### Superior life-cycle economics

It's a well-known industry fact that steam generator outages are the single largest contributor to reduced plant availability, which therefore determines the project's financial success (Figure 2). For example, consider a 600 MW supercritical coal plant that burns \$50/tonne (4500 kcal/kg) Indonesian coal and sells power at \$100/MWh at a base 90 per cent capacity factor.

A loss of four percentage points in annual capacity factor will reduce the plant's bottom line economics \$13.8 million for the first year, or \$212 million over its 30-year operating life. The CFB demonstrates up to an average 5.5 percentage point superiority in plant availability factor over 15 years, depending on fuel selection.

The cost of fuel is the largest line item on the balance sheet for any power plant so the economic advantage often goes to the plant that can operate reliably with lower rank, and therefore lower cost, fuels.

The magnitude of the fuel cost savings can be demonstrated by using the same



The DGF Suez Energia Polska Polaniec Plant entered commercial service in 2012.

supercritical plant example above firing \$70/tonne (5,500 kcal/kg) coal as a base. Reducing the cost of fuel by \$10/tonne will add \$7 million to the plant's bottom line for a single year and \$102 million over 30 years.

## Plant case studies

There are many recent projects that illustrate the successful application of Sumitomo SHI FW CFB technology in circumstances much like the above case study. The following four projects illustrate the fuel flexibility of the CFB, each in unique applications.

The Lagisza CFB Power plant is the longest operating supercritical CFB power plant in the world today. Located at Tauron's Lagisza power plant in Bedzin, Poland, the plant has been in operation since 2009.

At the heart of the plant is a 460 MW supercritical SFW CFB featuring many unique first-of-a-kind design features and a very impressive net plant efficiency of 43.3 per cent (LHV) on bituminous coal.

Perhaps most importantly, the plant meets its permitted stack emissions without SCR or FGD equipment, thereby saving Tauron

over \$100 million in its construction cost and millions more each year in avoided O&M costs.

CLECO's Brame Energy Center, located in Boyce, Louisiana, in the US, is noted for its ability to burn a wide-range of market fuels. The plant consists of twin CFB boilers feeding a single steam turbine generator the produces 660 MWe.

The plant is designed to burn multiple fuels, including 100 per cent petroleum coke, 100 per cent Illinois No. 6, 100 per cent sub-bituminous Powder River Basin coal, and can co-fire up to 92 per cent lignite or co-fire up to 5 per cent paper sludge or wood waste. The plant entered commercial service in February 2010.

The DGF Suez Energia Polska Polaniec Plant, located in Polaniec, Poland, is the world's largest biomass CFB power plant. The 205 MWe (gross) plant burns a spectrum of wood biomass and agricultural crops and byproducts. The net plant efficiency is 36.5% (LHV).

Perhaps the most impressive example of a utility-scale CFB plant is the 2200 MW

Samcheok Green Power Plant currently being commissioned in Samcheok, South Korea.

The Samcheok plant has four 550 MW Sumitomo SHI FW CFBs utilizing ultra-supercritical steam conditions (257 barg, 603C/603C). The plant will meet even tighter stack emissions without using FGD equipment, saving Korea's Southern Power Company (KOSPO) over \$250 million in construction costs.

The plant is designed to burn a wide range of import coals, including sub-bituminous high-moisture coals (20-42 per cent). The CFBs are also capable of co-firing indigenous bituminous coal and up to 5 per cent biomass. The plant is designed to operate with a 42.4 per cent net efficiency (LHV) and went into full commercial operation in December 2016, taking their place as the most advanced CFB units in the world.

Robert Giglio is Senior Vice President, Strategic Business Development, at Sumitomo SHI FW



Figure 1. The low temperature operation of the CFB reduces NO<sub>x</sub> emissions and limestone injection into the bed removes SO<sub>2</sub>.




Figure 2. Annual capacity factor is often the vital factor in a project's success. The net present value is based on a 30-year term and 5% discount rate.

**Others simply sell you a product – we offer a solution.**

OHL Gutermuth

A control and shut off technique you can rely on.

**Customized Valve Design**  
„MADE IN GERMANY“

ESD  
SOLAR  
POWER

OHL

Best Valves  
since 150  
Years

**OHL Gutermuth Industrial Valves GmbH**  
 Helmershäuser Str. 9+12 · 63674 Altenstadt / Germany  
 Phone +49.60 47.80 06-0 · Fax +49.60 47.80 06-29  
 www.ohl-gutermuth.de · og@ohl-gutermuth.de

For more information, enter 6 at pei.hotims.com